

Work Docket



Client Code: SRS01-001
Client Name: SRS Office PPM
Address: Unit 1 Northwest Centre
 North West Business Park

Parent Code: SRS01
Parent Name: SRS Office
Parent Address: Unit 1 Northwest Centre
 North West Business Park

ServiceCode: 2307
PO Number: PO 1236

Job ID:

Issue	Resolution
Q1 2020 Preventative Maintenance SRS061- Fire Extinguishers	Arrived on site as requested. All extinguishers serviced to IS291-2015 (EN3). All extinguisher safety signage present and to standards. All extinguishers comply with IS291-2015(EN3) standards ref pressure testing and test discharge. All test discharge completed to IS291-2015 (EN3). Fire register updated. Site contact advised of findings prior to departure

Name	Started Travel	Arrival Time	Departure Time
Ronan Behan	26/04/2020 14:45:00	26/04/2020 15:00:00	26/04/2020 16:00:00

Quotation Required:	No
---------------------	----

Labour Hours:	01:00h
Travel Hours:	00:30h

Total Office Hours:	00:00h
Total Evening Hours:	00:00h
Total Night And Weekend Hours:	01:30h
Total Hours:	01:30h

SRS Office PPM

Joe Bloggs

26/04/2020 11:52

Name: Ronan Behan

Name: Joe Bloggs

Procedure Plan - Extinguisher Service

Contract: n/a

Client: SRS Office PPM

Plant Item: /

Location: n/a

Serving: n/a

Model No: n/a

Serial No: n/a

All Extinguishers Serviced to IS291-2015	Yes
All Extinguisher Cylinders inspected and weighted	Yes
All Extinguisher handles and pins checked	Yes
All Extinguisher gauges serviced, pressurised	Yes
All safety tags replaced	Yes
All service labels legible and updated	Yes
All Extinguisher safety signs as per standard	Yes
Issue Certificate	Yes
All Extinguisher location sheets checked	Yes
All Extinguisher quantities verified	Yes
All immediate issues reported to site contact	Yes
Quantities of Extinguishers on site	5No 6ltr Foam and 5No 2Kg CO2
Quantity of Hose Reels on Site	
Fire and General Register Updated?	Yes
Fire Alarm Service Provider?	SRS Fire Systems
Comment	



Certificate Fire Extinguisher Service Certificate

Certificate Number: 2307-1

SRS Fire Systems Ltd

Unit 1 Northwest Centre, Northwest Business Park, Ballycoolin, Dublin 15.

Name of protected premises or owner: SRS Office PPM

Address of Protected premises: Unit 1 Northwest Centre North West Business Park Dublin Dublin 15 Ireland

**This is to certify that the fire extinguishers at the above premises
have been serviced and comply with IS291 (2015)**

Comments

Signature of Authorised person responsible for servicing of the system

Name: Ronan Behan

Position: Service Engineer

Signed

Date: 26/04/2020

Telephone number: 00353 1 885 3681